



Regd. Office & Terminal

Sy. No. 1, Exim Park Area, Ph : +0891 2868100
Opp. Naval Dockyard, Malkapuram Post, e-mail : ro@eastindiapetro.com
Visakhapatnam - 530 014. INDIA

EAST INDIA PETROLEUM PVT. LTD.

www.eastindiapetro.com CIN : U23209 AP1994PTC017623

Ref: EIPL/MOEF/2022-23/118

Date: 01-06-2022

The Director (S),
Regional Office - South Eastern Zone
Ministry of Environment, Forests and Climate Change,
Government of India,
1st and 2nd floor, HEPC Building
No.34, Cathedral Garden Road,
Nungambakkam,
Chennai - 600034.
E-mail: roefccc1@gmail.com
Tel: 044- 28222325.

Dear Sir,

Sub: CRZ clearance for additional LPG and POL pipelines and associated facilities for existing storage terminal at Port Exim park area, Visakhapatnam, Andhra Pradesh by M/s East India petroleum Pvt. Ltd- Submission of compliance report- Reg.

Ref: CRZ clearance letter no: F.No. 11-17/2013-IA.III dated: 17.10.2013.

With reference to the above, please find attached six monthly compliance reports for the period of October 2021 to March 2022.

For your kind perusal and records please.

Thanking you,
Yours faithfully,
For East India Petroleum Pvt. Ltd.,


S F H Sharief.
General Manager-Projects & Regulatory
Encl: As above

Corporate Office :

D.No. 6-3-871, Snehalatha, Ph : +91 40 6602 5555,
Greenlands Road, Begumpet, Fax : +91 40 6602 5533
Hyderabad-500 016. TELANGANA E-mail : ho@eastindiapetro.com



Compliance of Conditions vide CRZ approval dated 17.10.2013 Ref: F.No.11-17/2013-IA.III for the period of October 2021 - March 2022

01-06-2022

SI No	Conditions as per EC	Compliance as on date for the period of 1st October 2021 - 31st March 2022
A	Specific Conditions	
i)	"Consent for Establishment" shall be obtained from State Pollution Control Board under Air and Water Act and a copy shall be submitted to Regional office of this Ministry at Bengaluru before start of any construction work at the site.	Complied
ii)	All the conditions stipulated by Andhra Pradesh Coastal Zone Management Authority vide their letter No. 4907/CZMA/2012, dated 02.03.2013 shall be strictly complied with.	Complied
iii)	Norms of Oil Industries Safety Directorate(OISD) shall be followed in respect of storage and transport of LPG.	Complied
iv)	Monitoring of Volatile Organic Compounds(VOC) shall be carried out regularly.	Complied and it is in existing practice.
v)	Necessary signages shall be installed in both English and local languages wherever the pipeline is passing.	Complied
vi)	The smooth and safe operation of the system shall be ensured by incorporating a computerized SCADA (Supervisory Control And Data Automation) system. Any leakage in the pipeline shall be immediately detected by the Computer system and product pumping shall be immediately cut off.	Complied
vii)	All the recommendations mentioned in the EMP/DMP shall be complied with letter and spirit. All mitigation measures submitted in the EIA report shall be prepared in a matrix format and the compliance for each mitigation plan shall be submitted to MoEF along with half yearly compliance report to MoEF-RO.	Complied
viii)	Soil and water samples shall be regularly monitored along the pipeline route to check the leakage/contamination, if any and shall examined if any strengthening is required.	Complied
ix)	It shall be ensured that there is no disturbance to people, houses are fishing activity as a result of the project.	Complied
x)	Under Corporate Social Responsibility(CSR), sufficient budgetary provision shall be made for health improvement, education, water and electricity supply etc. in and around the project.	Complied and it is in existing practice.
xi)	The project proponent shall set up separate environmental management cell for effective implementation of the stipulated environmental safe guards under the supervision of a senior executive.	A safety and environmental management cell of 2 persons has been set up and is already functional.
xii)	The funds earmarked for environment management plan shall be included in the budget and this shall not be delivered for any other purpose.	Complied.
B.	General Conditions.	
i)	The construction of the structures should be undertaken as the plans approved by the concerned local authorities/ Local administration, meticulously confirming to the existing local and central rules and regulations including the provisions of Coastal Regulation Zone Notification, 2011 and the approved Coastal Zone Management Plan of Andhra Pradesh.	Complied



ii)	In the event of any change in the project profile a fresh reference shall be made to the Ministry Of the Environment and Forests.	Noted.
iii)	This Ministry reserves the right to revoke this clearance , if any of the conditions stipulated are not complied with to the satisfaction of this Ministry.	Noted.
iv)	This Ministry or any other competent authority may stipulate any additional conditions subsequently, if deemed necessary, for environmental protection, which shall be complied with.	Noted.
v)	Full support should be extended to the officers of this Ministries Regional office at Bangolore and the offices of the central and Andhra Pradesh State Pollution Control board by the project proponents during their inspection for monitoring purposes, by furnishing full details and action plans including the action taken reports in respect of imitative measures and other environmental protection activates.	Noted.

